



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong


電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (12) in WSD 3321/14 Pt.1 T/J(100)

2 September 2014



(Attn.: Ms Florence MOK)

Dear Madam,

### Approval of "BELLINI" Mechanical Mixers

Your letters ref. FM140603A and FM140603B both dated 3 June 2014 and subsequent submission received on 13 August 2014 refer.

Having considered test reports ref. 140673ST140095D and 140673ST140095(1)C both issued on 5 August 2014 by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** E&I International Limited

**Country of Origin:** China

**Brand:** Bellini

**Details of Fittings:**

1. 1/2" Single lever basin mixer w/o pop up waste  
Model: BA 8002
2. 1/2" Single lever bath-shower mixer  
Model: BA 8008

Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(LAM Ching Man)  
for Water Authority

c.c.      WSD 3321/1/82   ] - without catalogue  
            E/CS(TS)1       ]