



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail [wsdinfo@wsd.gov.hk](mailto:wsdinfo@wsd.gov.hk)

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (4) in WSD 3321/13 Pt.1 T/J(164)

16 July 2013

E & I International Limited  
9/F, Wing Tai Center,  
12 Hing Yip Street,  
Kwun Tong, Kowloon

(Attn.: Ms Fanny YAU)

Dear Madam,

### Approval of "BELLINI" Basin and Shower Mixers

Your letters ref. FY130703A, FY130703B and FY130703C all dated 3 July 2013 refer.

Having considered test report ref. 131090ST130176(1), 131090ST130176 and 131090ST130176(2) all issued on 14 June 2013 by the Fugro Technical Services Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** E & I International Ltd.

**Country of Origin:** China

**Brand:** Bellini

**Details of Fittings:**

1. 1/2" Single lever wash basin mixer  
Model no.: FQN32090 (PM16045C)
2. 1/2" Shower mixer  
Model no.: LG16008-612A
3. 1/2" Single lever wash basin mixer  
Model no.: BA8001

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-


“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(WONG Kwok Hung)  
for Water Authority



自願參與用水效益標籤計劃 - 水龍頭  
Voluntary Water Efficiency Labelling Scheme - Water Taps


Certificate of Registration  
註冊證書

茲證明  
This is to certify that

E & I INTERNATIONAL LIMITED

將下列水龍頭在本計劃內註冊：  
has registered the following water tap under this scheme :

牌子 / Brand	:	Bellini
型號 / Model	:	BA8001
種類 / Type	:	Mixing
原產地 / Country or Region Origin	:	China

在用水效益標籤上展示的標誌 <i>Symbolic Presentation on the Water Efficiency Label</i>	:		滴水點 <i>Water droplet(s)</i>
用水效益級別 <i>Water Efficiency Grade</i>	:	1	
耗水量 <i>Water Consumption</i>	:	3.6	公升/分鐘 <i>litres/minute</i>

簽發日期：  
Date of Issue: 15 October 2014

 水務署  
Water Supplies Department



水務署署長(林正文代行)  
for Director of Water Supplies