



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail

wsdinfo@wsd.gov.hk

電話
Telephone

2829 4367

圖文傳真
Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/13 Pt.1 T/J(12)

29 January 2013

E & I International Limited
9/F, Wing Tai Center,
12 Hing Yip Street,
Kwun Tong, Hong Kong

(Attn.: Ms Fanny Yau)

Dear Sir/Madam,

Approval of "Bellini" Self-closing Basin Tap

Your submissions in the letter ref. FY130111A, FY130111B and FY130111C all dated 11 January 2013 refer.

Having considered test reports ref. J16343A, J16343B and J16343C all issued on 8 January 2013 by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

- Name of Manufacturer:** E & I International Limited
- Country of Origin:** China
- Brand:** Bellini
- Details of Fittings:**
- (1) ½" Deck mounted basin tap (AC/DC)
Model no.: BL-GL-8880
 - (2) ½" Sleeve sensor basin tap (AC/DC)
Model no.: BL-GL-8881
 - (3) ½" Deck mounted sensor basin tap
Model no.: BL-GL-4448

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”


and

“Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Yours faithfully,



(WONG Kwok Hung)
for Water Authority