



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/14 Pt.1 T/J(42)

11 April 2014

E & I International Limited
8/F, Block B, Chung Mei Ctr.,
15 Hing Yip Street,
Kwun Tong, Kowloon,
Hong Kong

(Attn.: Ms Fanny YAU)

Dear Madam,

Approval of "BELLINI" Sensor Basin Taps

Your letters ref. FY140318A and FY140324B dated 18 March 2014 and 24 March 2014 respectively refer.

Having considered test report ref. J17239A issued on 11 March 2014 by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: E & I International Limited
Country of Origin: China
Brand: Bellini
Details of Fitting: 1/2" Deck mounted sensor basin tap
Models: BL-GL-4442-AC and BL-GL-4442-DC

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

“A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply.” AND


“The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(WONG Kwok Hung)
for Water Authority