



水務署
Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4367 圖文傳真
Facsimile 2824 0578

檔號
Reference (7) in WSD 3321/13 Pt.1 T/J(111)

3 June 2013

E & I International Limited
9/F, Wing Tai Center,
12 Hing Yip Street,
Kwun Tong, Kowloon

(Attn.: Ms Fanny YAU)

Dear Madam,

Approval of "BELLINI" Sensor Basin Taps

Your letters ref. FY130508A and FY130508B both dated 8 May 2013 and FY130522A dated 22 May 2013 refer.

Having considered test reports ref. J16697 and J16696-1 issued on 26 April 2013 and 21 May 2013 respectively by the Nutek Systems Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: E & I International Limited
Country of Origin: China
Brand: Bellini
Details of Fittings: 1/2" Deck mounted sensor basin tap
(1) Model no.: BL-GL-8886AC
(2) Model no.: BL-GL-8886DC
(3) Model no.: BL-GL-8882AC
(4) Model no.: BL-GL-8882DC

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,

(WONG Kwok Hung)
for Water Authority