



水務署  
Water Supplies Department

香港灣仔告士打道七號入境事務大樓  
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞  
e-mail wsdinfo@wsd.gov.hk

電話  
Telephone 2829 4367

圖文傳真  
Facsimile 2824 0578

檔號  
Reference (2) in WSD 3321/13 Pt.1 T/J(225)

28 August 2013

E & I International Limited  
9/F, Wing Tai Center,  
12 Hing Yip Street,  
Kwun Tong, Kowloon

(Attn.: Ms Fanny YAU)

Dear Madam,

**Approval of "BELLINI" Basin Mixer**

Your letter ref. FY130822D dated 22 August 2013 refers.

Having considered test report ref. J17083B issued on 20 August 2013 by the Nutek Systems, Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** E & I International Ltd.  
**Country of Origin:** China  
**Brand:** Bellini  
**Details of Fittings:** 3/8" Single lever wash basin mixer  
Model: BA-1004

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same

source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Ken H CHAN at tel. no. 2829 4453.

Yours faithfully,



(WONG Kwok Hung)  
for Water Authority